
**SECTION 00 1115
NOTICE OF PUBLIC HEARING**

**CAMANCHE WELL #7 PHASE 1 WELL AND PUMP
CITY OF CAMANCHE**

To Whom It May Concern:

You are hereby notified that at 6:00 PM, Central Time on February 06, 2024, at 818 7th Avenue, Camanche, IA 52730 will be a public hearing on the proposed plans, specifications, form of contract, and estimated cost of the project. Any persons interested may appear and file objections to the proposed plans, specifications, form of contract, or cost of such improvement.

The following is a description of the Public Improvement : Construction of a Potable Water Deep Well approximately 1,300 feet deep, with steel casing pipe in these approximate lengths and diameters: 60 feet of 24 inch, 375 feet of 18.625 inch, 900 feet of 14" diameter. Grouting, development of the well, disinfection, installation of a 650 gpm 580 TDH submersible well pump with associated pitless adapter and appurtenances for an operational well and pump system..

Proposed drawings, specifications, and form of contract may be examined at City Hall, during regular business hours.

Published by order of the City Council, Camanche, Iowa.

By: Andrew Kida

Title: City Administrator

END OF SECTION