

City of Camanche Water Quality Information 2023

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our water quality testing shows the following results:

CONTAMINANT	MCL-(MCLG)	Compliance		Date	Violation n	Source
		Type	Value & (Range)			
Lead (ppb)	AL=15 (0)	90th	2.00 (ND – 23) 1 sample Exceeded AL	2023	NO	Corrosion of household plumbing systems; erosion of natural microbes
Copper (ppm)	AL=1.3 (1.3)	90th	.35 (ND – 1.0)	2023	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
950-DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 MRDLG=4.0	RAA	1.3 (0.19 – 2.6)	12/31/2023	NO	Water additive used to control microbes
Total Coliform Bacteria	TT (TT)	RTCR	1 sample(s) positive	07/31/2023	NO	Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other waterborne pathogens may be present, or that a potential pathway exists through which contamination may enter the drinking water.
03 – S/EP WELL #5						
Gross Alpha, inc (pCi/L)	15 (0)	SGL	2.1	01/08/2020	NO	Erosion of natural deposits
Combined Radium (pCi/L)	5 (0)	SGL	1.2	01/08/2020	NO	Erosion of natural deposits
Fluoride (ppm)	4 (4)	SGL	0.54	12/04/2023	NO	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	110	12/04/2023	NO	Erosion of natural deposits; Added to water during treatment process
04 – S/EP WELL #6						
Nitrate [as N] (ppm)	10 (10)	SGL	3.7	2023	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
06 – S/EP WELL #3						
Barium (ppm)	2 (2)	SGL	0.07	7/18/2022	NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

PFAS Information

In 2023 our water system exceeded an EPA drinking water lifetime interim health advisory for the PFAS compound(s) shown below. Public notice was provided for these contaminants last year when we became aware of the situation. Please refer to that notification for more information regarding these results.

PFAS Compound	Date	Our Result (ppt)	Health Advisory Level (ppt)
PFOA	2023	7.8 (4.6 – 7.8)	0.004 (interim)
PFOS	2022	14 (6.8 - 14)	0.020 (interim)

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations

Definitions

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) – The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Ppb – parts per billion

- Ppm – parts per million
- pCi/L – picocuries per liter
- N/A -- Not applicable
- ND – Not detected
- RAA – Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants
- Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – Single Sample Result
- RTCR – Revised Total Coliform Rule
- NTU – Nephelometric Turbidity Units

GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminant does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline (800-426-4791)

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CAMANCHE WATER SUPPLY is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

OTHER VIOLATIONS

In September 2023 we failed to monitor for Inorganic (IOC) Chemicals. Adverse health effects, if any, are not known. Monitoring procedures have been corrected to avoid future violations.

In September 2023 we failed to monitor for Sodium. Adverse health effects, if any are not known. Monitoring procedures have been corrected to avoid future violations.

In September 2023 we failed to monitor for Inorganic (IOC) Chemicals. Adverse health effects, if any, are not known. Monitoring procedures have been corrected to avoid future violations.

SOURCE WATER ASSESSMENT INFORMATION

This water supply obtains its water from the sand and gravel of the Alluvial aquifer. The Alluvial aquifer was determined to be highly susceptible to contamination because the characteristics of the aquifer and overlying materials provide little protection from contamination at the land surface. The Alluvial wells will be highly susceptible to surface contaminants such as leaking underground storage tanks, contaminant spills, and excess fertilizer application. A detailed evaluation of your source water was completed by the Iowa Department of Natural Resources, and is available from you Water Operator at (563-259-9410)

This water supply also obtains water from the sandstone and dolomite of the *Cambrian-Ordovician* aquifer. The *Cambrian-Ordovician* aquifer was determined to be slightly susceptible to contamination because the characteristics of the aquifer and overlying materials provide moderate protection from contamination at the land surface. The *Cambrian-Ordovician* well will be slightly susceptible to surface contamination such as leaking underground storage tanks, contaminant spills, and excess fertilizer application. A detailed evaluation of your source water was completed by the Iowa DNR and is available from the Water Operator at (563-259-9410)

Contact Information:

If you have questions or comments about your drinking water, please call the CAMANCHE WATER SUPPLY at 563-259-9410. This report will not be mailed to you, please call us if you would like a copy.